

The County of Yuba

Administrative Services



TO: Board of Supervisors

FROM: Administrative Services, Perminder Bains

SUBJECT: Approve release of Request for Proposals for HVAC coil replacement at the Yuba County Government Center and authorize Administrative Services to distribute

DATE: October 25, 2022

NUMBER: 552/2022

Recommendation:

Administrative Services' staff recommends the Board of Supervisors approve release of Request for Proposals (RFP) for HVAC coil replacement at the Yuba County Government Center, and authorize Administrative Services' staff to distribute.

Background & Discussion:

The two air handler units (AHUs) located at the north end of the Government Center are original to the 2004 remodel of the facility. These coils are essential to the operation of the AHUs that provide proper airflow throughout the Government Center. Standard life expectancy for coils in units this size is approximately 20 years. Each time the coils leak it costs approximately \$4,000 in refrigerant due to the size of the AHUs. Replacing these coils will avoid leaks, a potential failure and will also promote energy efficiency. Estimated cost for this project is \$85,000.

Administrative Services recommends the Board approve the release of this RFP and authorize Administrative Services' staff to distribute.

Committee Action:

This item is brought directly to the Board of Supervisors due to the routine nature of this request.

Fiscal Impact:

There is no fiscal impact to release the RFP.

Attachments

552-2022 HVAC Coil Replacement RFP